



HENRY LAU, PH.D., P.E.
Senior Engineer
Customer Solutions
Design & Engineering Services

Telephone:
(626) 633-7179
Facsimile:
(626) 633-7197

June 1, 2003

Mr. Jack Wallace
Performance Cleaning Technologies, Inc.
596 Estabrook St.
San Leandro, CA 94577

Dear Mr. Wallace:

Thank you for the opportunity to review the material forwarded earlier this month. We have reviewed the data and web site information regarding the ADSIL "Microguard". Based on the two reports prepared by the Florida Solar Energy Center, and the report prepared by the Global Energy Group, the test results show a performance improvement ranged from no change on the new unit to 11.9% improvement on the unit estimated at 85% of its useful life. Based on those results, Microguard will be qualified for the Standard Performance Contract (SPC). You may contact SPC program manager, Grant Hjelsand, at 626-302-8131, or visit our web site <http://www.sce.com/> for details.

Thank you for calling our attention to this product.

Sincerely,

A handwritten signature in black ink, appearing to read "Grant Hjelsand".

cc: Grant Hjelsand
John Nall